



Proposed Code Change  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 11/17/09

Code 19.2.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY- ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

|   |       |                              |
|---|-------|------------------------------|
| Code Title<br><b>Indiana Residential Code</b>   |       | Edition<br><b>2009</b>       |
| Section number and title<br><b>302.11.2 Fireblocking Integrity</b>  |       | Page<br><b>1</b>             |
| Proponent<br><b>SW Indiana Builders and Building Officials</b>  | Title |                              |
| Address<br><b>2175 N Cullen Ave; Evansville, IN 47715</b>   |       | Phone<br><b>812-479-6026</b> |
| <b>Center Complex; Room 310; Evansville, IN 47708</b>   |       | <b>812-436-7868</b>          |
| <input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution<br>PROPOSED CODE CHANGE (Check One) |       |                              |
| <b>Add to end of section: "...until Certificate of Occupancy is issued."</b>  |       |                              |
| REASON  |       |                              |
| <b>After the Certificate of Occupancy is issued, contractors are not legally permitted onto private property to be sure fireblocking is maintained.</b>   |       |                              |
| REVIEW RECOMMENDATION   |       |                              |
| Approve   |       |                              |
| Disapprove  |       |                              |
| Approve as amended  |       |                              |
| Further Study   |       |                              |